



Pueblo Department of Public Health and Environment Laboratory 101 W. 9th Street Pueblo, CO 81003 (719) 583-4318 pueblohealth.org

If you have not pre-paid your sample(s) please consider this your INVOICE and results.

Navajo Western W	ater District			
705 Navajo Rd.				
Walsenburg CO 81	089			
Sample: 21-4776	PWSID	CO0128625	System Name:	Navajo Western Water District
Collector: Tom No	rthup	9/2/2021	8:04:00 AM	RTOR
Address: 62 Buffalo Dr N		Sar	mple Tap	County: Huerfano
Chlorine Residual: 0.45mg/L		Rou	utine Distribution	Fee for Sample: \$21.00
Received By:	Espeseth	9/2/2021	9:25:00 AM	
AnalysisMethod: Colilert				
Results:	Total Coliform:	Absent	E.coli Result:	Absent
	Results Date:	9/3/2021	10:00:00 AM	Analyst: Aguilar
	Comments:			
Navajo Western W	ater District			
705 Navajo Rd.				
Walsenburg CO 81	089			
Sample: 21-4777	PWSID	CO0128600	System Name:	Navajo Western Water District
Collector: Tom No	rthup	9/2/2021	7:40:00 AM	RTOR
Address: 993 Chickasaw		Sar	nple Tap	County: Huerfano
Chlorine Residual: 0.51mg/L		Rou	utine Distribution	Fee for Sample: \$21.00
Received By:	Espeseth	9/2/2021	9:25:00 AM	
AnalysisMethod:	Colilert			
Results:	Total Coliform:	Absent	E.coli Result:	Absent
	Results Date:	9/3/2021	10:00:00 AM	Analyst: Aguilar
	Comments:			

Friday, September 3, 2021

Page 1 of 1

Note: Compliance sample records are only maintained and available for five years (Reference 40 CFR 141.33). PDPHE laboratory includes chlorine residual data reported on the request for analysis form when sending results to Colorado Department of Public Health and Environment, Water Quality Control Division.

NOTICE: Effective 1-1-2020 fees for Colilert presence/absence testing will be \$21.00. Fees for Enumerated coliform and E. coli testing will be \$23.00.