## NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

## **OPERATIONS REPORT FOR February 2022**

Water Pumped: Resorts, 615,678 Estates, 126,955 = 742,633 gallons. Through 01/28/2022

Usage by Customers: 706,210 gallons Loss= 36,423 = 4.9% = 1.2 gpm

## Items Purchased:

Received Meter Assemblies from Dana Kepner, ordered 8/21

## Work Accomplished:

- 1. Passed the monthly coliform tests
- 2. Met with Charles Goin, CWP, CRWA.
- 4. Locate customer leaks.
- 5 Royal Electric resolved issue with low setpoint cutoff
- 6. Samsara Down at Site 2-B 1-22-22.
- 7. Ordered Generator and propane for Well #1.
- 8. Snow removal.

9.

2-9-2022

Request