



**NAVAJO WESTERN WATER DISTRICT**  
**705 Navajo Road; Walsenburg, CO 81089**  
**Telephone: 719-738-3130 / Email: [operator@nwwd.us](mailto:operator@nwwd.us)**

**NAVAJO WESTERN WATER DISTRICT**  
**OPERATIONS REPORT FOR FEBRUARY 2025**

**Water Pumped: Resorts, 494,327 Estates, 126,521 = 620,848 gallons. Through 02/28/2025**

**Usage by Customers: 593,835 = Loss 27,013 (4.3%)**

**Work Accomplished:**

- 1. Passed Monthly Coliform Tests.**
- 2. Navajo Rd. main Repair.**
- 3. Main site control box repair Royal Electric.**
- 4. Locates (Comanche Dr., 425 Ute., 434 Arapahoe., 4065 CR 510.).**
- 5. Resorts Solution discharge line replaced.**
- 6. Hypo chlorinator Injectors replaced; barrels serviced Resorts/Estates.**
- 7. VFD motor replacements for Resorts effluent pumps.**
- 8. Assisted customers with Leaks. (5012 Comanche Dr., 57 Cheyenne Pl.)**
- 9. Well #6 New motor control box, Meter replaced Certification next week.**
- 10. Nitrate & Fluoride samples collected and submitted.**
- 11. Augmentation report submitted to state.**
- 12. Meeting with Tim Core and main for meter programming tutorial.**
- 13. Haley CDPHE PN Certificate of delivery form submitted CCR will be updated.**

**Requests: Water Overage Articles.**

**Thank You All!**  
**Dave Rabideau ORC**