



NAVAJO WESTERN WATER DISTRICT
705 Navajo Road; Walsenburg, CO 81089
Telephone: 719-738-3130 / Email: operator@nwwd.us

NAVAJO WESTERN WATER DISTRICT
OPERATIONS REPORT FOR June 2025

Water Pumped: Resorts, 702,250 Estates, 141,178 = 843,428 gallons. Through 06/30/2025

Usage by Customers: 690,558 = Loss 152,870 (18.1%) Comanche Main (6/6/25) = 68,500 Choctaw service Line (6/30/25) = 62,000 Total: 130,500 Actual Loss of 22,370 Gallons (2.6%)

Work Accomplished:

- 1. Passed Monthly Coliform Tests.**
- 2. Filing #2 Lot #31,32 Tap Installed.**
- 3. Leak repair 22 Choctaw Dr.**
- 4. Locates (48 Choctaw, 3055 Comanche, 3010 Comanche).**
- 5. Royal Electric original monitoring system quote.**
- 6. Hypo chlorinator Injectors serviced; Resorts/Estates.**
- 7. Filing #3 Lot #17 Tap installed.**
- 8. Assisted customers with Leaks. (38 Choctaw Dr.)**
- 9. Generac generator.**
- 10. Augmentation report submitted to state.**
- 11. CCR posted online and in office, certificate of delivery uploaded to portal.**
- 12. No damage to 131. Navajo Rd. meter or components.**

Requests: Water Overage Articles. (none)

Thank You All!

Dave Rabideau ORC